

PRECISION USB TEMPERATURE AND HUMIDITY SENSOR, WITH FILTER

TRH320



DESCRIPTION

The TRH320 is designed explicitly for environmental temperature and humidity acquisition. Thanks to its factory-calibrated, linearized, and temperature-compensated digital sensor chip, it is field interchangeable. With its precision electronics, highly slight variations in temperature and humidity can be detected. The compact probe eases integration, even in space-constrained locations, and the built-in particle filter provides protection against dust, soot, and other contaminants.

APPLICATIONS

- OEM
- Greenhouse
- Server rooms
- Manufacturing
- o Pre-certification
- LIMS integration
- Humidity control
- Scientific research
- Building automation
- Engineering and R&D
- Environmental chamber

INSTALLATION TIME

Less than 10 minutes

UNIQUE SERIAL NUMBER

Each unit is assigned a unique serial number allowing for traceability and certification

FREE DAQ SOFTWARE

Real-time data visualization and logging

DATA INTEGRATION

Command-line tools for direct data access and integration

OPTIONS

- Virtual COM Port (VCP) communication protocol
- 3-point user calibration mechanism

ALSO AVAILABLE

Traceability certificates

This product should not be used in applications where its failure may cause personal injury. Warning:

While every effort has been made to ensure accuracy in this publication, no responsibility can be accepted for errors or ornissions. omissions.

Data may change without notification, and you are strongly advised to obtain copies of the recently issued datasheet.

SPECIFICATIONS						
Parameter	Condition		Value	Units		
Temperature						
Operating range ^[1]	-40 to	70°C		Max	-	
Accuracy	0 to 70°C Typ. Max.		±0.2 ±0.4	°C		
Accuracy	-40 to 0°C Typ.		±0.3 ±0.4	°C		
Accuracy	-40 to 70°	-40 to 70°C Typ.		±0.3 ±0.4	°C	
Resolution	Ту	p.		0.01	°C	
Repeatability	Ту	p.		0.06	°C	
Response time	t63	3%		10	S	
Factory calibrated	Individually ^[2]		yes	-		
Long-term drift	Max.		< 0.03	°C/yr		
Relative humidit	Relative humidity					
Operating range ^[3]	Non-conden	sing	-	0 to 100	%RH	
Accuracy	0 to 90 %RH	25°C	Typ. Max	±2 ±2.5	%RH	
Accuracy	90 to 100 %RH	25°C	Typ. Max	±2.5 ±3.5	%RH	
Accuracy	0 to 100 %RH	0 to 70°C	Typ. Max.	±2.5 ±3.5	%RH	
Resolution	Тур.		0.01	%RH		
Hysteresis	25°C		0.8	%RH		
Factory calibrated	Individually ^[2]		Yes	-		
Long-term drift ^[5]	Typ., -40 to 70°C		< 0.25	%RH/y		
Probe						
Cable material		PVC				
Cable length	1 (3)			m (ft)		
First filter material	Polyethylene terephthalate (PET) mesh					
Sec. filter material	PTFE membrane					
Efficiency	Particle size ≥200 nm		99.99	%		


SPECIFICATIONS					
Parameter	Condition	Value	Units		
Power supply					
Voltage	Powered through a USB port	5	V		
Current consumption	At 5V	≤18	mA		
Mechanical					
Dimensions	See schema below	-	-		
Colour	-	Cyan	-		
Weight (without USB cable)	-	40	g		
Housing and USB cal	ole				
Temperature operating range	-	0 to 70	°C		
Humidity operating range	Non condensing	10 to 90	%RH		
Material	-	ABS	_		
IP rating ^[3]	-	51	-		
System galvanic isolation	-	None	-		
USB cable length	-	1 (3)	m (ft)		
Miscellaneous					
ADC resolution	-	16	bits		
Long-term stability	-	Yes	-		
Temperature compensated	By the manufacturer	Yes	-		
Lifetime	-	5	years		
Certification(s)					
RoHS	RoHS3	Yes	_		
CE	CE/REACH	Yes			

- $^{[1]}$ Only if the cable is not moved/flexed while the temperature is below 0°C.
- Each sensor is individually conditioned by the manufacturer of the semiconductor sensor chips in the best stable conditions, and their correction coefficients are recorded for each of them.
- If water condensation or splashing is possible, installing the probe pointing down is recommended to reduce the risk of water build-up in the sensor. If water splashing is possible, take extra precautions to protect the sensor and the cable converter. Depending on the application, extra housing may be
- Typical value for operation in average relative humidity and temperature range. Maximum value is $<0.5\ \text{MRH/yr}$. Higher drift values might occur due to contaminant environments with vaporized solvents, out-gassing tapes, adhesives, packaging materials, etc. For optimal perfomance, keep the unit in a contaminant free (VOCs) and well ventilated area.






www.dracal.com



AVAILABLE CHANNEL(S) As displayed in our logging software					
CHANNEL ID*	DECRIPTION	TYPE	NATURE		
00	SHT31 Temperature	Temperature	Real		
01	SHT31 Relative Humidity	Relative Humidity	Real		
02	Dew point	Dew point	Virtual		
03	Humidex	Humidex	Virtual		
04	Heat index	Heat index	Virtual		

^{*} Channel ID as it appears in DracalView. Virtual channel IDs differ in DracalView and dracal-usb-get.



PRUDUCT(5)			
PART NUMBER	OPTION	DESCRIPTION	
601032	USB-TRH320	Precision USB temperature and humidity sensor, with filter	
608032	USB-TRH320-CAL	Precision USB temperature and humidity sensor, with filter - calibratable	
603032	VCP-TRH320	Precision USB temperature and humidity sensor, with filter - with VCP mode	
605032	VCP-TRH320-CAL	Precision USB temperature and humidity sensor, with filter - calibratable with VCP mode	
TRACEABILITY CERTIFICATE(S)			
NT1WT	1-point temperature certificate for one (1) unit		
NT2WT	2-point temperature certificate for one (1) unit		
NT3WT	3-point temperature certificate for one (1) unit		
NT4WT	4-point temperature certificate for one (1) unit		
NT1WH	1-point relative humidity certificate for one (1) unit		
NT2WH	2-point relative humidity certificate for one (1) unit		
NT3WH	3-point relative humidity certificate for one (1) unit		
NT4WH	4-point relative humidity certificate for one (1) unit		

ORDERING

DRUDIICT/C

CAUTION: Please remember that electromagnetic interference (EMI) may decrease the accuracy of the sensor. Avoid using this device near EMI sources such as motors, high-voltage transformers, and fluorescent tubes.

NOTE: Note that this product is not waterproof and requires protection if contact with water is possible.

TIP: Avoid installing the sensor in a location where strong vibration is likely to occur. Strong vibrations may cause slight inaccuracies in the reading.

TIP: Before using any precision measurement equipment, it is advised to power the unit for at least 15 minutes.

Dracal Technologies Inc. All Rights Reserved

REV. September 6, 2024

www.dracal.com

Sales: sales@dracal.com General Inquiries: info@dracal.com

Technical Support:

Visit us at: www.dracal.com

Dracal Technologies Inc. 7900 Taschereau Blvd. Building A, suite 204 Brossard, QC, Canada J4X 1C2